

[Click here](#) for Comm 383 Private Onsite wastewater treatment systems [PDF](#) Appendix [PDF](#)

[TestPOWTS30](#)

[3 hours of credit](#)

Fees: \$30

[Back to home page](#)

Course: 6890 "INTERNET" TESTPOWTS30

This course is valid for these credentials:

Credential Description	Cred Code	Credit Hours
Commercial Plumbing Inspector	CPI	3.0
Journeyman Plumber	PJ	3.0
Journeyman Plumber-Restricted Service	PJRS	3.0
Master Plumber	PM	3.0
Master Plumber-Restricted Service	PMRS	3.0
POWTS Inspector	PI	3.0
Soil Tester	ST	3.0

1. Comm 383 applies to all of the following:
 - a. A situation where domestic wastewater is collected and conducted by means of plumbing drain systems and is not conveyed to a wastewater treatment facility regulated by the department of natural resources.
 - b. A POWTS where domestic wastewater is treated and dispersed to the subsurface.
 - c. A holding tank that is utilized as a POWTS or as part of a POWTS to collect or hold domestic wastewater for transport or treatment elsewhere.
 - d. only a & b
2. Chapter 383 does not apply to:
 - a. A POWTS owned by the federal government and located on federal lands
 - b. A POWTS located or to be located on land owned by the federal government for Native Americans.
 - c. both a & b
 - d. a only
3. A modification to an existing POWTS, including the replacement, alteration or addition of materials, appurtenances or POWTS components, shall require that the modification conform to this chapter.
 - a. true
 - b. false
4. When an addition or alteration is proposed to an existing building, structure or facility that is served by an existing POWTS and the proposed addition or alteration will result in a change that affects the wastewater flow or wastewater contaminant load beyond the minimum or maximum capabilities of the existing POWTS, the POWTS shall be modified to conform to the rules of this chapter.
 - a. true
 - b. false
5. Chapter 383 does not apply retroactively to an existing POWTS installed prior to _____.
 - a. July 1, 2000
 - b. July 1, 2001
 - c. June 1, 2000
 - d. June 1, 2001

6. An existing POWTS installed prior to December 1, 1969 with an infiltrative surface of a treatment and dispersal component that is located less than 2 feet above groundwater or bedrock shall be considered to discharge final effluent that is sewage, unless proven otherwise.
- true
 - false
7. An existing POWTS which conforms with this chapter shall be permitted to remain as_____.
- installed
 - grand fathered
 - conforming non compliant
 - legal non conforming
8. The department shall consider a restriction or a prohibition placed on a lot or an out lot prior to _____, as a result of its plat review authority under s. 236.12, Stats., waived, if a POWTS proposed for the lot complies with this chapter.
- July 31, 2000
 - July 15, 2000
 - July 1, 2001
 - July 1, 2000
9. A governmental unit may issue a sanitary permit for the construction or use of a POWTS that utilizes any of the technologies, designs or methods delineated in _____.
- Table 383.04-2
 - Table 383.04-1
 - Table 383.05-1
 - Table 383.06-1
10. Only courses, programs and seminars approved in writing by the department shall be used to fulfill the required training for the POWTS technologies and methods under _____.
- SPS 383.04 (1)
 - 383.21 (2) (c) 4.730
 - Both a & b
 - None of the above
11. An individual who has completed the installation and inspection training shall be responsible for retaining evidence of achieving the training in order to fulfill the obligations under _____.
- Both b & c
 - SPS 383.04 (1)
 - 383.21 (2) (c) 4
 - None of the above
12. SPS 383.20 Purpose. (1) This subchapter establishes the following:
- Regulatory processes and procedures which are to be followed when designing, installing or maintaining a POWTS.
 - Responsibilities and actions of the various governmental agencies involved with the administration and enforcement of this chapter only.
 - None of the above
 - Both a & b
13. SPS 383.20 Purpose. Except as provided in this chapter nothing shall limit the authority and power of a governmental unit in exercising _____responsibilities regarding a POWTS, including requiring and issuing other types of permits for activities not covered under this subchapter relating to sanitary permits.
- None of the below
 - Both c & d
 - enforcement
 - administration

14. The installation or construction of a POWTS may not commence or continue unless all of the following have been fulfilled:
- The owner of the property on which the POWTS is to be installed possesses a valid sanitary permit.
 - Plan approval for the POWTS has been obtained in accordance with s. Comm 383.22.
 - A building permit has been secured.
 - Only a & b
15. The modification of an existing POWTS may not commence or continue unless the owner of the property on which the POWTS is located possesses a valid sanitary permit and has obtained plan approval for the modification under s. Comm 383.22, if the modification involves the addition or replacement of any of the following:
- A POWTS holding component.
 - A POWTS treatment component.
 - A POWTS dispersal component.
 - a, b & c
16. The application for a sanitary permit shall be made in a format prescribed by the County having jurisdiction.
- true
 - false
17. A sanitary permit may not be issued until the plans and specifications have been approved by the department or local municipality having jurisdiction.
- a . true
 - false
18. A governmental unit shall review and make a determination on the submission of an application for a sanitary permit within ____days after receiving all the required information.
- 7
 - 14
 - 30
 - 60
19. If upon review of the application and the supporting information, the governmental unit or the department determines that the proposed design, installation and management of the POWTS or the proposed modification of an existing POWTS conforms to this chapter, a sanitary permit may be issued.
- true
 - false
20. If upon review of the application and the supporting information, the governmental unit or the department determines that the proposed design, installation and management of the POWTS or the proposed modification of an existing POWTS does not conform to this chapter, a sanitary permit may be issued.
- true
 - false
21. The appeal of the denial by the department for a sanitary permit shall be made in writing within ____ days from the date of the decision.
- 7
 - 14
 - 30
 - 60
22. A sanitary permit may be transferred from an owner to a subsequent owner.
- true
 - false

23. A sanitary permit shall expire ____ years from the date of issuance.
- 1
 - 2
 - 3
 - 4
24. The application for renewal of a sanitary permit shall be submitted to the department within ____ days of expiration.
- 7
 - 14
 - 30
 - neither a, b or c
25. Plans shall be submitted to the department, a designated agent or the governmental unit in accordance with this section for all of the following types of installations or modifications:
- The installation or construction of a POWTS.
 - The replacement or addition of a POWTS treatment component.
 - The replacement or addition of a POWTS holding component.
 - a, b & c
26. When plans are submitted to the department or designated agent for review, at least ____ sets of plans and one set of specifications shall be provided.
- 2
 - 3
 - 1
 - 4
27. Plans submitted for review shall include all of the following:
- Details and configuration layouts depicting how the design is to be constructed and how the design is to accomplish the treatment in accordance with ss. Comm 383.43 and 383.44 and dispersal that is claimed or the holding of wastewater.
 - Specifications, including a description of the materials for the project and the installation or construction practices and methods to be employed.
 - A site plan with a bench mark either scaled or dimensioned, delineating all treatment and dispersal components and their relationship to any items listed in Table 383.43-1.
 - a, b & c
28. The department shall review and make a determination on the submission of a plan within ____ business days after receiving all the required information and fees.
- 7
 - 14
 - 15
 - 30
29. The department may revoke any plan approval issued under this section for any false statements or misrepresentation of facts on which the approval was based within ____ days.
- 7
 - 15
 - 30
 - neither a, b or c
30. If a plan approval is revoked, the installation or alteration of a POWTS may not continue until another plan approval has been submitted.
- true
 - false

31. When plans are required to be approved by the department or designated agent the plumber responsible for the installation of a POWTS or the modification of an existing POWTS shall keep at the construction site at least one set of plans bearing evidence of approval by the department or designated agent and at least one copy of specifications.

- a. true
- b. false

testpowts 30

- 1 a b c d
- 2 a b c d
- 3 a b c d
- 4 a b c d
- 5 a b c d
- 6 a b c d
- 7 a b c d
- 8 a b c d
- 9 a b c d
- 10 a b c d

- 11 a b c d
- 12 a b c d
- 13 a b c d
- 14 a b c d
- 15 a b c d
- 16 a b c d
- 17 a b c d
- 18 a b c d
- 19 a b c d
- 20 a b c d

- 21 a b c d
- 22 a b c d
- 23 a b c d
- 24 a b c d
- 25 a b c d
- 26 a b c d
- 27 a b c d
- 28 a b c d
- 29 a b c d
- 30 a b c d
- 31 a b c d

To obtain your Continuing Education Credits follow the below instructions.

- 1. Print out first.
- 2. Fill in all fields applicable. **Fee \$30**
- 3. Include your certification or license number if applicable.
- 4. We'll take care of crediting with the state and sending you back a verification form.

Send by mail

- 1. **The answer sheet and this page only.**
- 2. Fill out this form below completely.
- 3. Applicable fees by check payable to Gary Klinka.
- 4. Mail to: Gary Klinka at 228 Mandella Ct Neenah WI 54956.
- 5. Office 920-727-9200 Fax 888-727-5704 Cell 920-740-4119 or 920-740-6723
- 6. Email: garyklinka@hotmail.com

-----Educational Course Attendance Verification Form -----

Attendee's Name _____ Date _____

Address _____

Credential Number _____ Phone# _____

Course Title and Name _____ testpowts30 _____

List each credential held by attendee _____

_____ Credited Hours _____ 3hrs Fee: \$30 _____

Email address _____ Fax# _____

To be completed by Gary Klinka www.garyklinka.com My credential link [#70172](#)

Course Password _____ Course ID# _____ 6890 _____

Attendee passed the course with a greater than 70% score on Date _____

Instructor Signature _____